

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08382
Name of Facility: Angelou, Maya El
Address: 1850 NW 32nd Street
City, Zip: Miami 33142

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: MDCPS
Person In Charge: Maria Gancedo-Guzman Phone: (305) 636-3480
PIC Email: mgancedo@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 7/8/2024

Begin Time: 10:12 AM
End Time: 12:01 PM

Additional Information

FEMALES 293
MALES 349
CENSUS 642

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
OUT 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	OUT 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
OUT 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory.

Email Address(es): mgancedo@dadeschools.net;
azapirain@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #2. Playground, Equipment & Athletic Fields Observed playground wall/fence corner with missing cement blocks and exposed iron rods with Caution Tape around the area to avoid student's access. Repair playground wall/fence.</p> <p>CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5(2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.</p>
<p>Violation #5. Maintenance & Repair Observed wall outlet cover plate cracked in classroom 040. Replace cover. Observed evidence of ceiling water leaking in classroom 079 and missing ceiling tile. Repair water leaking source and replace ceiling tile. Observed hole on floor with missing tiles in bathroom 096-1 and missing floor tiles in Bathroom 097-1. Repair floor and replace tiles. Observed ceiling lighting fixture with light tubes burn out in classroom 028. Replace light tubes. Observed handwashing sink draining pipes leaking water in classroom 070. Repair draining pipes connections.</p> <p>CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.</p>
<p>Violation #9. Mechanical Ventilation Observed exhaust fans not functioning in bathrooms 028-2, 042-1, 089-1, 113-1, 113-2, 119-1. Repair/Replace exhaust fans.</p> <p>CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.</p>
<p>Violation #14. Soap Dispensers Observed soap dispenser missing in handwashing sink of classrooms 33 and bathrooms 047, 016-2, 016-3. Replace soap dispenser. Operator provided soap dispensers.</p> <p>CODE REFERENCE: 14. Soap Dispensers. 468.3.5.7.2 FBC. Soap dispensers for liquid, foam or powdered soap shall be provided at all handwashing basins. 5(10)(f) SREF. Dispensers for liquid, foam, or powdered soap shall be maintained in a safe & secure condition at all times.</p>

Inspection Conducted By: Vicente Prietodiaz (31113)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Amalia Zapirain
Date: 7/8/2024

Inspector Signature:

Client Signature: